Eaton 051846

Eaton Moeller® series DIULE Reversing contactor combination, 380 V 400 V: 4 kW, 110 V 50 Hz, 120 V 60 Hz, AC operation

| PRODUCT NAME | Eaton Moeller® series DIULE contactor combination |
|-------------------------|---|
| CATALOG NUMBER | 051846 |
| PRODUCT LENGTH/DEPTH | 94 mm |
| PRODUCT HEIGHT | 61 mm |
| PRODUCT WIDTH | 90 mm |
| PRODUCT WEIGHT | 0.451 kg |
| CERTIFICATIONS | CSA File No.: 012528 CSA-C22.2 No. 14-05 IEC/EN 60947-4-1 CSA UL File No.: E29096 CSA Class No.: 3211-04 UL 508 CE UL Category Control No.: NLDX UL |
| CATALOG NOTES | IE3-ready devices are identified by the logo on their packaging. |



| ELECTRICAL CONNECTION TYPE FOR AUXILIARY-AND CONTROL-CURRENT CIRCUIT NUMBER OF POLES FEATURES Mechanical interlock The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THE RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the entire switchgear needs to be evaluated. | | |
|--|--|---|
| The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. | CONNECTION TYPE FOR AUXILIARY- AND CONTROL-CURRENT | Screw connection |
| 10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RISSITANCE 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION The panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. | NUMBER OF POLES | Three-pole |
| 10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.5 LIFTING 10.2.5 LIFTING 10.2.6 Lifting 10.2.6 Lifting 10.2.7 Lifting 10.2.8 responsibility. The specifications for the switchgear must be observed. 10.4 device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. | FEATURES | Mechanical interlock |
| 10.11 SHORT-CIRCUIT RATING responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING PINSUL STAPPL PRODUCT STANDARD PRODUCT PRODUCT STANDARD PRODUCT STANDARD PRODUCT STANDARD PRODUCT PRODUCT PRODUCT STANDARD PRODUCT PROD | 10.10 TEMPERATURE RISE | responsible for the temperature rise calculation. Eaton will provide heat dissipation |
| 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING Personsibility. The specifications for the switchgear needs to be evaluated. The device meets the requirements the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Meets the product standard's requirements. | | responsibility. The specifications for the switchgear must be |
| 10.13 MECHANICAL FUNCTION requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. | | responsibility. The specifications for the switchgear must be |
| RESISTANCEstandard's requirements.10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURESMeets the product standard's requirements.10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEATMeets the product | | requirements, provided the information in the instruction leaflet (IL) is |
| THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. | | • |
| RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. | THERMAL STABILITY OF | - |
| INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. | RESISTANCE OF INSULATING MATERIALS | • |
| ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. | INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. | - |
| 10.2.5 LIFTING entire switchgear needs to be evaluated. | ULTRA-VIOLET (UV) | |
| 10.2.6 MECHANICAL Does not apply, since the | 10.2.5 LIFTING | entire switchgear needs to |
| | 10.2.6 MECHANICAL | Does not apply, since the |

| DECLARATIONS OF | eaton-contactor- combination-declaration- |
|-----------------|--|
| CONFORMITY | of-conformity- uk251249en.pdf |
| MCAD MODEL | <u>diule.stp</u> <u>diule.dwg</u> |
| | <u>IL03407067Z</u> |

| IMPACT | entire switchgear needs to be evaluated. |
|--|---|
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | ls the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | ls the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | ls the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | ls the panel builder's responsibility. |
| POLLUTION DEGREE | 3 |
| UTILIZATION CATEGORY | AC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off during running |
| CONNECTION | Screw terminals |
| AMBIENT OPERATING | 50 °C |
| TEMPERATURE - MAX | 30 C |
| AMBIENT OPERATING TEMPERATURE - MIN | -25 °C |
| AMBIENT OPERATING | |
| AMBIENT OPERATING TEMPERATURE - MIN AMBIENT OPERATING TEMPERATURE | -25 °C |
| AMBIENT OPERATING TEMPERATURE - MIN AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX AMBIENT OPERATING TEMPERATURE | -25 °C 40 °C |
| AMBIENT OPERATING TEMPERATURE - MIN AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN AMBIENT STORAGE | -25 °C 40 °C -25 °C |

| TEMPERATURE - MIN | |
|---|--|
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID | 2.45 W |
| HEAT DISSIPATION CAPACITY PDISS | 0 W |
| HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID | 0.82 W |
| APPLICATION | Contactor combinations for starting motors with two directions of rotation |
| PRODUCT CATEGORY | Contactor combinations |
| ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT | Screw connection |
| VOLTAGE TYPE | AC |
| DEGREE OF PROTECTION | IP20 NEMA Other |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 2 |
| NUMBER OF CONTACTS (NORMALLY CLOSED) AS MAIN CONTACT | 0 |
| NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACT) | 6 |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MAX | 110 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN | 110 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX | 120 V |
| RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN | 120 V |
| OVERVOLTAGE CATEGORY | III |
| DUTY FACTOR | 100 % |
| INTERFERENCE IMMUNITY | According to EN 60947-1 |
| FUNCTIONS | Reversing safety |
| RATED CONTROL SUPPLY VOLTAGE (US) AT DC - | 0 V |

| MAX | |
|---|---------------------------------------|
| RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN | 0 V |
| RATED INSULATION VOLTAGE (UI) | 690 V |
| RATED OPERATIONAL CURRENT (IE) AT AC-1, 380 V, 400 V, 415 V | 9 A |
| RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V | 9 A |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 9 A |
| RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ | 4 kW |
| RATED OPERATIONAL POWER AT AC-4, 220/230 V, 50 HZ | 1.5 kW |
| RATED OPERATIONAL POWER AT AC-4, 660/690 V, 50 HZ | 3 kW |
| RATED OPERATIONAL POWER (NEMA) | 3.7 kW |
| STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS | 1.8 W |
| SUITABLE FOR | Also motors with efficiency class IE3 |
| RATED OPERATIONAL POWER AT AC-3, 690 V, 50 HZ | 4 kW |
| ACTUATING VOLTAGE | 110 V 50 Hz, 120 V 60 Hz |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) | 0 |
| NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS) | 0 |
| VOLTAGE TYPE OF OPERATING VOLTAGE | AC |
| OPERATING VOLTAGE AT AC, 50 HZ - MIN | 24 V |
| OPERATING VOLTAGE AT AC, 50 HZ - MAX | 690 V |
| OPERATING VOLTAGE AT | 24 V |

| AC, 60 HZ - MIN | |
|--------------------------------------|-------|
| OPERATING VOLTAGE AT AC, 60 HZ - MAX | 690 V |
| OPERATING VOLTAGE AT DC - MIN | 0 V |
| OPERATING VOLTAGE AT DC - MAX | 0 V |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| : | |
| | |



Eaton House 30 Pembroke Road Dublin 4, Eaton.com

Follow us on social media to get the latest product and support information.









