

## Eaton 065011

Eaton Moeller® series Conversion kit on main switch, handle black, for T0-/E-/Z

0000	
PRODUCT NAME	Eaton Moeller® series Accessory Insulated enclosure
CATALOG NUMBER	065011
PRODUCT LENGTH/DEPTH	50 mm
PRODUCT HEIGHT	48 mm
PRODUCT WIDTH	48 mm
PRODUCT WEIGHT	0.07 kg
CERTIFICATIONS	UL/CSA certification not required



ТҮРЕ	<ul> <li>Assembly kit</li> <li>Main switch     assembly kit</li> <li>With black rotary     handle and black     locking ring</li> </ul>
10.10 TEMPERATURE RISE	The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.
10.11 SHORT-CIRCUIT RATING	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.12 ELECTROMAGNETIC COMPATIBILITY	Is the panel builder's responsibility. The specifications for the switchgear must be observed.
10.13 MECHANICAL FUNCTION	The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.
10.2.2 CORROSION RESISTANCE	Meets the product standard's requirements.
10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES	Meets the product standard's requirements.
10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT	Meets the product standard's requirements.
10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS	Meets the product standard's requirements.
10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION	Meets the product standard's requirements.
10.2.5 LIFTING	Does not apply, since the entire switchgear needs to be evaluated.
10.2.6 MECHANICAL IMPACT	Does not apply, since the entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product

## 

eaton-rotary-switchesaccessory-3d-drawing-003.eps

	standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
FITTED WITH:	Padlocking feature
ACCESSORY/SPARE PART TYPE	Mounting set
COLOR	Black
AMBIENT OPERATING TEMPERATURE - MAX	50 °C
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
	-25 °C
TEMPERATURE - MIN  EQUIPMENT HEAT  DISSIPATION, CURRENT-	
TEMPERATURE - MIN  EQUIPMENT HEAT  DISSIPATION, CURRENT- DEPENDENT PVID  HEAT DISSIPATION	0 W
TEMPERATURE - MIN  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID  HEAT DISSIPATION CAPACITY PDISS  HEAT DISSIPATION PER POLE, CURRENT-	0 W
TEMPERATURE - MIN  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID  HEAT DISSIPATION CAPACITY PDISS  HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID  RATED OPERATIONAL CURRENT FOR SPECIFIED	0 W 0 W
TEMPERATURE - MIN  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID  HEAT DISSIPATION CAPACITY PDISS  HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID  RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)  STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT	0 W 0 W 0 W
TEMPERATURE - MIN  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT PVID  HEAT DISSIPATION CAPACITY PDISS  HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT PVID  RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)  STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT PVS	0 W 0 W 0 A 0 W

mounting switch T.../Z (with FS908 front plate) into interlocked rear mounting main switch T.../V/SVB For converting flush mounting switch T.../E into flush mounting main switch T.../EA/SVB...

**PROJECT NAME:** 

**PROJECT NUMBER:** 

**PREPARED BY:** 

00:



Eaton House 30 Pembroke Road Dublin 4, □□□ Eaton.com

© 2025 🛛 🖺 🖺 🖺

Follow us on social media to get the latest product and support information.









