Eaton 107595

Eaton Moeller series NZM - Molded Case Circuit Breaker. Circuit-breaker, 3p, 200A, box terminals, N2-VEF200-BT-NA

PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker electronic
CATALOG NUMBER	107595
PRODUCT LENGTH/DEPTH	149 mm
PRODUCT HEIGHT	195 mm
PRODUCT WIDTH	105 mm
PRODUCT WEIGHT	2.345 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	Specially designed for North America CE marking IEC 60947-2 UL listed CSA (Class No. 1432-01) IEC CSA certified CSA-C22.2 No. 5-09 UL/CSA UL (File No. E31593) UL 489 IEC/EN 60947 UL (Category Control Number DIVQ) CSA (File No. 22086)



AMPERAGE RATING 200 A VOLTAGE RATING 690 V - 690 V CIRCUIT BREAKER FRAME TYPE NZM2 FEATURES Motor drive optional Protection unit 10.10 TEMPERATURE RISE The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 MECHANICAL FUNCTION The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE Meets the product standard's requirements. 10.2.3.1 VERIFICATION OF ENCLOSURES Meets the product standard's requirements. 10.2.3.2 VERIFICATION OF ENCLOSURES Meets the product standard's requirements. 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT Meets the product standard's requirements. 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. 10.2.6 MECHANICAL INGERIAL STANDER TO SURVE STANDER TO SURVE STANDER TO SURVE STANDER TO SURVE STANDER TO		
TYPE FEATURES Motor drive optional Protection unit The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THERMAL STABILITY OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.	AMPERAGE RATING	200 A
FEATURES Motor drive optional Protection unit The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.	VOLTAGE RATING	690 V - 690 V
10.10 TEMPERATURE RISE 10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL 10.2.6 MECHANICAL The panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the		NZM2
10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF TINSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL Tresponsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.	FEATURES	· ·
10.11 SHORT-CIRCUIT RATING responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING PINOLED MECHANICAL POSE NOT apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL PISTOR SWITCH STREED SWITCH STREED SWITCH STREED SWITCH STREED SWITCH S	10.10 TEMPERATURE RISE	responsible for the temperature rise calculation. Eaton will provide heat dissipation
10.12 ELECTROMAGNETIC COMPATIBILITY responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the		responsibility. The specifications for the switchgear must be
requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the		responsibility. The specifications for the switchgear must be
RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the evaluated.		requirements, provided the information in the instruction leaflet (IL) is
THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the		-
RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	THERMAL STABILITY OF	·
INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the	RESISTANCE OF INSULATING MATERIALS	•
ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the entire switchgear needs to be evaluated.	INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT.	•
10.2.5 LIFTING entire switchgear needs to be evaluated.10.2.6 MECHANICAL Does not apply, since the	ULTRA-VIOLET (UV)	-
	10.2.5 LIFTING	entire switchgear needs to

	eaton-circuit-breaker- current-nzm-mccb- characteristic-curve- 006.eps
CHARACTERISTIC CURVE	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 054.eps
	eaton-circuit-breaker-nzm- mccb-characteristic-curve- 043.eps
DECLARATIONS OF CONFORMITY	DA-DC-03 N2
	eaton-circuit-breaker-nzm- mccb-dimensions-019.eps

	be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	Is the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
POLLUTION DEGREE	3
MOUNTING METHOD	DIN rail (top hat rail) mounting optional Built-in device fixed built- in technique Fixed
CLIMATIC PROOFING	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	33 W
UTILIZATION CATEGORY	A (IEC/EN 60947-2)
ISOLATION	300 V AC (between the auxiliary contacts) 500 V AC (between auxiliary contacts and main contacts)
AMBIENT OPERATING TEMPERATURE - MAX	70 °C
AMBIENT OPERATING	-25 °C

TEMPERATURE - MIN	
AMBIENT STORAGE TEMPERATURE - MAX	70 °C
AMBIENT STORAGE TEMPERATURE - MIN	40 °C
LOW-VOLTAGE HBC FUSE - MAX	355 A gG/gL
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
PROTECTION AGAINST DIRECT CONTACT	Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110
DEGREE OF PROTECTION	IP20 (basic degree of protection, in the operating controls area) IP20
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Frame clamp
LIFESPAN, MECHANICAL	20000 operations
OVERVOLTAGE CATEGORY	III
RATED OPERATIONAL CURRENT	200 A (660-690 V AC-3, making and breaking capacity) 200 A (690 V AC-1, making and breaking capacity) 300 A (415 V AC-1, making and breaking capacity) 300 A (380/400 V AC-1, making and breaking capacity)
DEGREE OF PROTECTION (IP), FRONT SIDE	IP66 (with door coupling rotary handle) IP40 (with insulating surround)
DEGREE OF PROTECTION (TERMINATIONS)	IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal)
NUMBER OF POLES	Three-pole
TERMINAL CAPACITY	Min. 2 segements of 16

(COPPER STRIP)	mm x 0.8 mm at rear-side connection (punched) Max. 10 segments of 16 mm x 0.8 mm at box terminal Min. 2 segments of 9 mm x 0.8 mm at box terminal Max. 10 segments of 16 mm x 0.8 mm at rear-side connection (punched)
LIFESPAN, ELECTRICAL	10000 operations at 400 V AC-1 5000 operations at 690 V AC-3 7500 operations at 690 V AC-1 6500 operations at 400 V AC-3 6500 operations at 415 V AC-3
FUNCTIONS	Current limiting circuit breaker Systems, cable, selectivity and generator protection
TYPE	Circuit breaker
SPECIAL FEATURES	 Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity Icn) Rated current = rated uninterrupted current: 200 A Switches conform to UL/CSA as well as the IEC regulations. IEC switching performance values are contained on the rating plate. Fixed overload releases Ir R.m.s. value measurement and

"thermal memory" • adjustable time delay setting to overcome current peaks tr: 2 – 20 s at 6 x lr • Adjustable delay time tsd: Steps: 0, 20, 60, 100, 200, 300, 500, 750, 1000 ms • i²t constant function: fixed OFF
 Branch circuits, feeder circuits Use in unearthed supply systems at 690 V
20 g (half-sinusoidal shock 20 ms)
Front side
200 A
33 W
Electronic release
< 10 ms
1.9 kA
1.9 kA
2000 A
400 A
2400 A
2400 A 2400 A

TERMINAL CAPACITY (COPPER BUSBAR)	Max. 20 mm x 5 mm direct at switch rear-side connection Min. 16 mm x 5 mm direct at switch rear-side connection M8 at rear-side screw connection
TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE)	6 mm ² - 11 mm ² (1x) direct at switch rear-side connection 6 mm ² - 12 mm ² (1x) at box terminal 16 mm ² (1x) at tunnel terminal
TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)	16 mm² (1x) at tunnel terminal
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	4 mm ² - 350 mm ² (1x) at box terminal 4 mm ² - 3/0 mm ² (1x) direct at switch rear-side connection 4 mm ² - 350 mm ² (1x) at tunnel terminal
HANDLE TYPE	Rocker lever
SHORT DELAY CURRENT SETTING (ISD) - MAX	2000 A
SHORT DELAY CURRENT SETTING (ISD) - MIN	400 A
INSTANTANEOUS CURRENT SETTING (II) - MAX	2400 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	2400 A
NUMBER OF OPERATIONS PER HOUR - MAX	120
OVERLOAD CURRENT SETTING (IR) - MAX	200 A
OVERLOAD CURRENT SETTING (IR) - MIN	200 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	85 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ	50 kA

RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	35 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	25 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	5 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	105 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	74 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	53 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
STANDARD TERMINALS	Box terminal
RATED OPERATING VOLTAGE UE (UL) - MAX	600Y/347 V, 480 V
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ	187 kA
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS	6000 V
RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS	8000 V
RATED INSULATION VOLTAGE (UI)	1000 V AC

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
:	



Eaton House 30 Pembroke Road Dublin 4, Eaton.com

Follow us on social media to get the latest product and support information.









