Eaton 111874

Eaton Moeller series Power Defense -Molded Case Circuit Breaker. Circuitbreaker, 4 p, 80A, B, 1

| PRODUCT NAME | Eaton Moeller series Power Defense molded case circuit-breaker |
|-------------------------|--|
| CATALOG NUMBER | 111874 |
| PRODUCT LENGTH/DEPTH | 88 mm |
| PRODUCT HEIGHT | 145 mm |
| PRODUCT WIDTH | 120 mm |
| PRODUCT WEIGHT | 1.324 kg |
| COMPLIANCES | RoHS conform |
| CERTIFICATIONS | VDE 0660 IEC IEC/EN 60947 |



| AMPERAGE RATING | 80 A |
|--|--|
| VOLTAGE RATING | 440 V - 440 V |
| CIRCUIT BREAKER FRAME TYPE | LZM1 |
| FEATURES | Protection unit |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |

| CHARACTERISTIC CURVE | eaton-circuit-breaker-nzm-mccb-characteristic-curve-051.eps eaton-circuit-breaker-characteristic-power-defense-mccb-characteristic-curve-038.eps eaton-circuit-breaker-characteristic-power- |
|----------------------|--|
| | defense-mccb- characteristic-curve- 032.eps |
| | eaton-circuit-breaker- switch-nzm-mccb- dimensions-014.eps |
| | eaton-circuit-breaker-nzm- mccb-dimensions-018.eps |

| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
|--|---|
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | Is the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | ls the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | Is the panel builder's responsibility. |
| POLLUTION DEGREE | 3 |
| MOUNTING METHOD | DIN rail (top hat rail) mounting optional Built-in device fixed built- in technique Fixed |
| CLIMATIC PROOFING | Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78 |
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT | 16.32 W |
| UTILIZATION CATEGORY | A (IEC/EN 60947-2) |
| ISOLATION | 300 V AC (between the auxiliary contacts) 500 V AC (between auxiliary contacts and main contacts) |
| NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS) | 0 |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY | 0 |

| CLOSED CONTACTS) | |
|---|---|
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS) | 0 |
| PROTECTION AGAINST DIRECT CONTACT | Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110 |
| DEGREE OF PROTECTION | In the area of the HMI devices: IP20 (basic protection type) IP20 |
| DIRECTION OF INCOMING SUPPLY | As required |
| ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT | Frame clamp |
| CURRENT RATING OF NEUTRAL CONDUCTOR | 200% of phase conductor |
| LIFESPAN, MECHANICAL | 20000 operations |
| OVERVOLTAGE CATEGORY | III |
| RATED OPERATIONAL CURRENT | 80 A (660-690 V AC-3, making and breaking capacity) 125 A (415 V AC-1, making and breaking capacity) 160 A (380/400 V AC-1, making and breaking capacity) 80 A (415 V AC-3, making and breaking capacity) |
| DEGREE OF PROTECTION (IP), FRONT SIDE | IP40 (with insulating surround) IP66 (with door coupling rotary handle) |
| DEGREE OF PROTECTION (TERMINATIONS) | IP00 (terminations, phase isolator and band terminal) IP10 (tunnel terminal) |
| NUMBER OF POLES | Four-pole |
| TERMINAL CAPACITY (COPPER STRIP) | Min. 2 segments of 9 mm x 0.8 mm at box terminal Max. 9 segments of 9 mm x 0.8 mm at box terminal |
| LIFESPAN, ELECTRICAL | 7500 operations at 400 V AC-1 7500 operations at 415 V AC-3 10000 operations at 415 V AC-1 |

| FUNCTIONS | System and cable protection |
|---|--|
| ТҮРЕ | Circuit breaker |
| SPECIAL FEATURES | Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn) Rated current = rated uninterrupted current: 80 A Set value in neutral conductor is synchronous with set value Ir of main pole. |
| APPLICATION | Use in unearthed supply systems at 440 V |
| SHOCK RESISTANCE | 20 g (half-sinusoidal shock 20 ms) |
| POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT | Front side |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 80 A |
| RELEASE SYSTEM | Thermomagnetic release |
| SHORT-CIRCUIT TOTAL BREAKTIME | < 10 ms |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX | 800 A |
| SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN | 480 A |
| TERMINAL CAPACITY (CONTROL CABLE) | 0.75 mm ² - 2.5 mm ² (1x) 0.75 mm ² - 1.5 mm ² (2x) |
| TERMINAL CAPACITY (COPPER BUSBAR) | Max. 16 mm x 5 mm direct at switch rear-side connection Min. 12 mm x 5 mm direct at switch rear-side |

| | connection M8 at rear-side screw connection |
|---|---|
| TERMINAL CAPACITY (COPPER SOLID CONDUCTOR/CABLE) | 10 mm ² - 16 mm ² (1x) at box terminal 6 mm ² - 16 mm ² (2x) direct at switch rear-side connection 6 mm ² - 16 mm ² (2x) at box terminal 16 mm ² - 95 mm ² (1x) at tunnel terminal 10 mm ² - 16 mm ² (1x) direct at switch rear-side connection |
| TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE) | 16 mm² (1x) at tunnel terminal |
| TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE) | 25 mm² (2x) at box terminal 25 mm² - 70 mm² (1x) direct at switch rear-side connection 25 mm² - 70 mm² (1x) at box terminal 25 mm² - 95 mm² (1x) at tunnel terminal 25 mm² (2x) direct at switch rear-side connection |
| TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE) | 25 mm² - 95 mm² (1x) at tunnel terminal |
| HANDLE TYPE | Rocker lever |
| SHORT DELAY CURRENT SETTING (ISD) - MAX | 0 A |
| SHORT DELAY CURRENT SETTING (ISD) - MIN | 0 A |
| INSTANTANEOUS CURRENT SETTING (II) - MAX | 800 A |
| INSTANTANEOUS CURRENT SETTING (II) - MIN | 480 A |
| NUMBER OF OPERATIONS PER HOUR - MAX | 120 |
| OVERLOAD CURRENT SETTING (IR) - MAX | 80 A |
| OVERLOAD CURRENT | 63 A |

| OVERLOAD CURRENT SETTING (IR) | 63 A - 80 A |
|--|--------------|
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ | 30 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ | 25 kA |
| RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ | 18.5 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ | 53 kA |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ | 53 kA |
| STANDARD TERMINALS | Box terminal |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ | 63 kA |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS | 6000 V |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS | 6000 V |
| RATED INSULATION VOLTAGE (UI) | 690 V AC |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| : | |



Follow us on social media to get the latest product and support information.









