

00000

## Eaton 113521

Eaton Moeller series NZM - Molded Case Circuit Breaker. Circuit-breaker, 4p, 500A, 230A in 4th pole, withdrawable unit

| 0000                    |  |
|-------------------------|--|
| PRODUCT NAME            | Eaton Moeller series NZM<br>molded case circuit<br>breaker thermo-magnetic |
| CATALOG NUMBER          | 113521   |
| PRODUCT<br>LENGTH/DEPTH | 346 mm   |
| PRODUCT HEIGHT          | 260 mm   |
| PRODUCT WIDTH           | 230 mm   |
| PRODUCT WEIGHT          | 12.9 kg  |
| COMPLIANCES             | RoHS conform   |
| CERTIFICATIONS          | IEC<br>IEC/EN 60947  |



| 0000   |  |
|--|--|
| AMPERAGE RATING  | 500 A  |
| VOLTAGE RATING   | 690 V - 690 V  |
| CIRCUIT BREAKER FRAME TYPE   | NZM3   |
| FEATURES   | Protection unit<br>Motor drive optional  |
| ACCESSORIES REQUIRED   | NZM3-4-XAVS  |
| 10.10 TEMPERATURE RISE   | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT<br>RATING  | ls the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.12 ELECTROMAGNETIC COMPATIBILITY  | ls the panel builder's responsibility. The specifications for the switchgear must be observed.                                   |
| 10.13 MECHANICAL<br>FUNCTION   | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.                         |
| 10.2.2 CORROSION<br>RESISTANCE   | Meets the product standard's requirements.   |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES                         | Meets the product standard's requirements.   |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT       | Meets the product standard's requirements.   |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements.   |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION                                 | Meets the product standard's requirements.   |
| 10.2.5 LIFTING   | Does not apply, since the entire switchgear needs to be evaluated.   |
| 10.2.6 MECHANICAL<br>IMPACT  | Does not apply, since the entire switchgear needs to be evaluated.   |

| CHARACTERISTIC CURVE | eaton-circuit-breaker-nzm-<br>mccb-characteristic-curve-<br>035.eps                         |
|----------------------|---|
|                      | eaton-circuit-breaker-nzm-<br>mccb-characteristic-curve-<br>032.eps                         |
|                      | eaton-circuit-breaker-<br>tripping-characteristic-<br>nzm-mccb-characteristic-<br>curve.eps |
| 00000                | eaton-circuit-breaker-<br>basic-device-nzmn-b-<br>il01208009z.pdf                           |
|                      | eaton-circuit-breaker-nzm-<br>mccb-dimensions-021.eps                                       |
|                      | eaton-circuit-breaker-<br>withdrawable-unit-nzm-<br>mccb-dimensions-002.eps                 |
|                      | eaton-circuit-breaker-<br>switch-nzm-mccb-<br>dimensions-016.eps                            |

| 10.2.7 INSCRIPTIONS  | Meets the product standard's requirements.  |
|--|---|
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES  | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES   | Meets the product standard's requirements.  |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK   | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS   | Does not apply, since the entire switchgear needs to be evaluated.  |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS  | ls the panel builder's responsibility.  |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS   | ls the panel builder's responsibility.  |
| 10.9.2 POWER-<br>FREQUENCY ELECTRIC<br>STRENGTH  | ls the panel builder's responsibility.  |
| 10.9.3 IMPULSE<br>WITHSTAND VOLTAGE  | ls the panel builder's responsibility.  |
| 10.9.4 TESTING OF  | ls the panel builder's  |
| ENCLOSURES MADE OF INSULATING MATERIAL   | responsibility.   |
|  | responsibility.   |
| INSULATING MATERIAL  |   |
| INSULATING MATERIAL POLLUTION DEGREE   | 3 Withdrawable Built-in device slide-in   |
| POLLUTION DEGREE  MOUNTING METHOD  | Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to  |
| INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT-  | Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78   |
| INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT  | Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78   |
| INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT  UTILIZATION CATEGORY  | Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  130.5 W  A (IEC/EN 60947-2)  500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the                     |
| INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT  UTILIZATION CATEGORY  ISOLATION  AMBIENT OPERATING                                      | Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  130.5 W  A (IEC/EN 60947-2)  500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) |
| INSULATING MATERIAL  POLLUTION DEGREE  MOUNTING METHOD  CLIMATIC PROOFING  EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT  UTILIZATION CATEGORY  ISOLATION  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING | Withdrawable Built-in device slide-in technique (withdrawable)  Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78  130.5 W  A (IEC/EN 60947-2)  500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts) |

| NUMBER OF AUXILIARY<br>CONTACTS (CHANGE-<br>OVER CONTACTS) | 0   |
|--|---|
| NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)    | 0   |
| NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)      | 0   |
| PROTECTION AGAINST<br>DIRECT CONTACT                       | Finger and back-of-hand<br>proof to DIN EN<br>50274/VDE 0106 part 110   |
| DEGREE OF PROTECTION                                       | IP20<br>IP20 (basic degree of<br>protection, in the<br>operating controls area)   |
| DIRECTION OF INCOMING SUPPLY                               | As required   |
| ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT                 | Screw connection  |
| CURRENT RATING OF NEUTRAL CONDUCTOR                        | 320 A<br>60% of phase conductor   |
| LIFESPAN, MECHANICAL                                       | 15000 operations  |
| OVERVOLTAGE<br>CATEGORY                                    | III   |
| DEGREE OF PROTECTION<br>(IP), FRONT SIDE                   | IP66 (with door coupling<br>rotary handle)<br>IP40 (with insulating<br>surround)  |
| DEGREE OF PROTECTION (TERMINATIONS)                        | IP00 (terminations, phase isolator and strip terminal)  |
|  | IP10 (tunnel terminal)  |
| NUMBER OF POLES  | Four-pole   |
| TERMINAL CAPACITY<br>(COPPER STRIP)                        | Min. 6 segments of 16 mm x 0.8 mm at box terminal 10 segments of 50 mm x 1 mm (2x) at rear-side width extension Max. 10 segments of 32 mm x 1 mm + 5 segments of 32 mm x 1 mm at rear-side connection (punched) |
|  | Max. 10 segments of 24<br>mm x 1 mm + 5 segments<br>of 24 mm x 1 mm<br>Min. 6 segments of 16 mm<br>x 0.8 mm at rear-side<br>connection (punched)<br>Max. 8 segments of 24<br>mm x 1 mm (2x) at box<br>terminal  |

| LIFESPAN, ELECTRICAL                                  | 2000 operations at 415 V<br>AC-3<br>2000 operations at 400 V<br>AC-3<br>3000 operations at 690 V<br>AC-1<br>2000 operations at 690 V<br>AC-3<br>5000 operations at 400 V<br>AC-1<br>5000 operations at 415 V<br>AC-1   |
|---|--|
| FUNCTIONS   | System and cable protection  |
| ТҮРЕ  | Circuit breaker  |
| SPECIAL FEATURES                                      | <ul> <li>Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity lcn)</li> <li>Rated current = rated uninterrupted current: 500 A</li> <li>Reduced neutral conductor protection</li> <li>Set value in neutral conductor is synchronous with set value Ir of main pole.</li> <li>Terminal capacity hint: Up to 240 mm² can be connected depending on the cable manufacturer.</li> </ul> |
| APPLICATION   | Use in unearthed supply systems at 690 V   |
| SHOCK RESISTANCE                                      | 20 g (half-sinusoidal shock<br>20 ms)  |
| POSITION OF<br>CONNECTION FOR MAIN<br>CURRENT CIRCUIT | Front side   |
| RATED OPERATIONAL CURRENT FOR SPECIFIED               | 500 A  |

| HEAT DISCIDATION (IN)                                     |  |
|---|--|
| HEAT DISSIPATION (IN) RELEASE SYSTEM                      | Thermomagnetic release   |
| SHORT-CIRCUIT TOTAL<br>BREAKTIME                          | Thermomagnetic release   |
| RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)            | 3.3 kA   |
| RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)              | 3.3 kA   |
| SHORT-CIRCUIT RELEASE<br>NON-DELAYED SETTING -<br>MAX     | 5000 A   |
| SHORT-CIRCUIT RELEASE<br>NON-DELAYED SETTING -<br>MIN     | 3000 A   |
| TERMINAL CAPACITY<br>(CONTROL CABLE)                      | 0.75 mm <sup>2</sup> - 1.5 mm <sup>2</sup> (2x)<br>0.75 mm <sup>2</sup> - 2.5 mm <sup>2</sup> (1x)   |
| TERMINAL CAPACITY<br>(COPPER BUSBAR)                      | Max. 30 mm x 10 mm + 30 mm x 5 mm direct at switch rear-side connection Max. 10 mm x 50 mm (2x) at rear-side width extension Min. 20 mm x 5 mm direct at switch rear-side connection M10 at rear-side screw connection |
| TERMINAL CAPACITY<br>(COPPER SOLID<br>CONDUCTOR/CABLE)    | 16 mm² (1x) at tunnel terminal 16 mm² (2x) direct at switch rear-side connection 16 mm² (1x) direct at switch rear-side connection 300 mm² (2x) at rear-side width extension 16 mm² (2x) at box terminal               |
| TERMINAL CAPACITY (ALUMINUM SOLID CONDUCTOR/CABLE)        | 16 mm² (1x) at tunnel<br>terminal  |
| TERMINAL CAPACITY<br>(COPPER STRANDED<br>CONDUCTOR/CABLE) | 35 mm² - 240 mm² (1x) at box terminal 25 mm² - 240 mm² (2x) direct at switch rear-side connection 25 mm² - 240 mm² (1x) direct at switch rear-side connection 16 mm² - 185 mm² (1x) at 1-hole tunnel terminal          |

|  | 25 mm² - 120 mm² (2x) at<br>box terminal  |
|--|---|
| TERMINAL CAPACITY<br>(ALUMINUM STRANDED<br>CONDUCTOR/CABLE)                              | 25 mm <sup>2</sup> - 185 mm <sup>2</sup> (1x) at<br>tunnel terminal<br>50 mm <sup>2</sup> - 240 mm <sup>2</sup> (1x) at<br>2-hole tunnel terminal<br>50 mm <sup>2</sup> - 240 mm <sup>2</sup> (2x) at<br>2-hole tunnel terminal |
| HANDLE TYPE  | Rocker lever  |
| SHORT DELAY CURRENT<br>SETTING (ISD) - MAX   | 0 A   |
| SHORT DELAY CURRENT<br>SETTING (ISD) - MIN   | 0 A   |
| INSTANTANEOUS<br>CURRENT SETTING (II) -<br>MAX   | 10 A  |
| INSTANTANEOUS<br>CURRENT SETTING (II) -<br>MIN   | 6 A   |
| NUMBER OF<br>OPERATIONS PER HOUR -<br>MAX  | 60  |
| OVERLOAD CURRENT<br>SETTING (IR) - MAX   | 500 A   |
| OVERLOAD CURRENT<br>SETTING (IR) - MIN   | 400 A   |
| OVERLOAD CURRENT<br>SETTING (IR)   | 250 A - 320 A   |
| RATED SHORT-CIRCUIT<br>BREAKING CAPACITY ICS<br>(IEC/EN 60947) AT 230 V,<br>50/60 HZ     | 55 kA   |
| RATED SHORT-CIRCUIT<br>BREAKING CAPACITY ICS<br>(IEC/EN 60947) AT<br>400/415 V, 50/60 HZ | 36 kA   |
| RATED SHORT-CIRCUIT<br>BREAKING CAPACITY ICS<br>(IEC/EN 60947) AT 440 V,<br>50/60 HZ     | 22.5 kA   |
| RATED SHORT-CIRCUIT<br>BREAKING CAPACITY ICS<br>(IEC/EN 60947) AT 525 V,<br>50/60 HZ     | 9 kA  |
| RATED SHORT-CIRCUIT<br>BREAKING CAPACITY ICS<br>(IEC/EN 60947) AT 690 V,<br>50/60 HZ     | 4 kA  |
| RATED SHORT-CIRCUIT<br>MAKING CAPACITY ICM<br>AT 400/415 V, 50/60 HZ                     | 76 kA   |
| RATED SHORT-CIRCUIT MAKING CAPACITY ICM  | 63 kA   |

| AT 440 V, 50/60 HZ   |   |
|--|---|
| RATED SHORT-CIRCUIT<br>MAKING CAPACITY ICM<br>AT 525 V, 50/60 HZ | 24 kA   |
| RATED SHORT-CIRCUIT<br>MAKING CAPACITY ICM<br>AT 690 V, 50/60 HZ | 14 kA   |
| STANDARD TERMINALS   | Screw terminal                                    |
| OPTIONAL TERMINALS   | Box terminal. Connection on rear. Tunnel terminal |
| RATED SHORT-CIRCUIT<br>MAKING CAPACITY ICM<br>AT 240 V, 50/60 HZ | 121 kA  |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS     | 6000 V  |
| RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS          | 8000 V  |
| RATED INSULATION<br>VOLTAGE (UI)                                 | 1000 V AC   |

**PROJECT NAME:** 

**PROJECT NUMBER:** 

**PREPARED BY:** 



Eaton House 30 Pembroke Road Dublin 4, □□□ Eaton.com

latest product and support information.







Follow us on social media to get the



