Eaton 165527

RCD/MCB, 16A, 30mA, miniature circuitbreaker trip curve C, 1pole+N, residual current circuit-breaker trip characteristic: AC. PFL6-16/1N/C/003-G

| PRODUCT NAME | Eaton Moeller series xPole - PFL6/7 RCBO - residual- current circuit breaker with overcurrent protection |
|-------------------------|--|
| CATALOG NUMBER | 165527 |
| PRODUCT LENGTH/DEPTH | 86 mm |
| PRODUCT HEIGHT | 75 mm |
| PRODUCT WIDTH | 37 mm |
| PRODUCT WEIGHT | 0.207 kg |
| COMPLIANCES | CE Marked |
| CERTIFICATIONS | CE |



| VOLTAGE RATING | 230 V |
|---|--|
| SURGE CURRENT CAPACITY | 3 kA |
| VOLTAGE TYPE | AC |
| WIDTH IN NUMBER OF MODULAR SPACINGS | 2 |
| FEATURES | Concurrently switching N- neutral Anti-nuisance tripping version |
| 10.10 TEMPERATURE RISE | The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. |
| 10.11 SHORT-CIRCUIT RATING | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.12 ELECTROMAGNETIC COMPATIBILITY | Is the panel builder's responsibility. The specifications for the switchgear must be observed. |
| 10.13 MECHANICAL FUNCTION | The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. |
| 10.2.2 CORROSION RESISTANCE | Meets the product standard's requirements. |
| 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES | Meets the product standard's requirements. |
| 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT | Meets the product standard's requirements. |
| 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS | Meets the product standard's requirements. |
| 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION | Meets the product standard's requirements. |
| 10.2.5 LIFTING | Does not apply, since the |

eaton-xpole-pfl7-rcbo-catalog-ca019045en-en-us.pdf

eaton-xpole-pfl6-rcbo-catalog-ca019046en-en-us.pdf

| | entire switchgear needs to be evaluated. |
|---|--|
| 10.2.6 MECHANICAL IMPACT | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.2.7 INSCRIPTIONS | Meets the product standard's requirements. |
| 10.3 DEGREE OF PROTECTION OF ASSEMBLIES | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.4 CLEARANCES AND CREEPAGE DISTANCES | Meets the product standard's requirements. |
| 10.5 PROTECTION AGAINST ELECTRIC SHOCK | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS | Does not apply, since the entire switchgear needs to be evaluated. |
| 10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS | Is the panel builder's responsibility. |
| 10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS | ls the panel builder's responsibility. |
| 10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH | ls the panel builder's responsibility. |
| 10.9.3 IMPULSE WITHSTAND VOLTAGE | Is the panel builder's responsibility. |
| 10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL | ls the panel builder's responsibility. |
| OPERATING AMBIENT TEMPERATURE - MAX | 40 °C |
| OPERATING AMBIENT TEMPERATURE - MIN | -25 °C |
| RATED CURRENT | 16 A |
| RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN) | 16 A |
| STATIC HEAT DISSIPATION, NON- CURRENT-DEPENDENT | 0 W |
| BUILT-IN DEPTH | 69.5 mm |
| CURRENT LIMITING CLASS | 3 |
| RATED SHORT-CIRCUIT BREAKING CAPACITY (EN 60947-2) | 0 kA |

| FAULT CURRENT RATING | 0.03 A |
|---|--|
| HEAT DISSIPATION CAPACITY | 0 W |
| HEAT DISSIPATION PER POLE, CURRENT- DEPENDENT | 0 W |
| NUMBER OF POLES (PROTECTED) | 1 |
| NUMBER OF POLES (TOTAL) | 2 |
| BASIC FUNCTION | Combined RCD/MCB devices |
| EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT | 3.2 W |
| DEGREE OF PROTECTION | IP20 |
| OVERVOLTAGE CATEGORY | Ш |
| POLLUTION DEGREE | 2 |
| LEAKAGE CURRENT TYPE | AC |
| RELEASE CHARACTERISTIC | С |
| FREQUENCY RATING | 50 Hz |
| NUMBER OF POLES | Single-pole + N |
| ТҮРЕ | RCBO |
| APPLICATION | Switchgear for residential and commercial applications |

| PROJECT NAME: | |
|-----------------|--|
| PROJECT NUMBER: | |
| PREPARED BY: | |
| : | |



Follow us on social media to get the latest product and support information.











Dublin 4, Eaton.com

Eaton House

30 Pembroke Road