Eaton 183343

Eaton Moeller series IZMX/INX - ACB. Circuitbreaker, 3p, 1000A, 42 kA, Selective operation, IEC, Withdrawable

PRODUCT NAME	Eaton Moeller series IZMX/INX circuit-breaker
CATALOG NUMBER	183343
PRODUCT LENGTH/DEPTH	584 mm
PRODUCT HEIGHT	597 mm
PRODUCT WIDTH	521 mm
PRODUCT WEIGHT	27.74 kg
COMPLIANCES	IEC/EN 60947 IEC RoHS conform



USED WITH Air circuit breaker Air circuit breaker Air circuit breakers/switch-disconnector AMPERAGE RATING 1000 A Motor drive optional Complete device with protection unit The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THE SISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the entire switchgear needs to be evaluated.		
FEATURES Motor drive optional Complete device with protection unit The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. In 10.11 SHORT-CIRCUIT RATING Is the panel builder's responsibility. The specifications for the switchgear must be observed. In 10.12 ELECTROMAGNETIC COMPATIBILITY In 10.13 MECHANICAL FUNCTION In 2.2 CORROSION RESISTANCE In 2.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES In 10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES In 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT In 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT In 2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated.	USED WITH	Air circuit breakers/switch-
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF ENCLOSURES 10.2.3.2 VERIFICATION OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING The panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. In device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	AMPERAGE RATING	1000 A
10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.5 LIFTING 10.2.5 LIFTING 10.2.6 Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	FEATURES	Complete device with
10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.5 LIFTING 10.2.5 LIFTING IS the panel builder's responsibility. The specifications for the switchgear must be observed. 1he device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	10.10 TEMPERATURE RISE	responsible for the temperature rise calculation. Eaton will provide heat dissipation
10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.5 LIFTING The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements.		responsibility. The specifications for the switchgear must be
10.13 MECHANICAL FUNCTION requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE Meets the product standard's requirements. 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated.		responsibility. The specifications for the switchgear must be
RESISTANCEstandard's requirements.10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURESMeets the product standard's requirements.10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEATMeets the product standard's requirements.10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTSMeets the product standard's requirements.10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATIONMeets the product standard's requirements.10.2.5 LIFTINGDoes not apply, since the entire switchgear needs to be evaluated.		requirements, provided the information in the instruction leaflet (IL) is
THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.		·
RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	THERMAL STABILITY OF	-
INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	RESISTANCE OF INSULATING MATERIALS	·
ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT.	-
10.2.5 LIFTING entire switchgear needs to be evaluated.	ULTRA-VIOLET (UV)	
10.2.6 MECHANICAL Does not apply, since the	10.2.5 LIFTING	entire switchgear needs to
	10.2.6 MECHANICAL	Does not apply, since the

TT-IZMX16B3-V10W-1-
<u>183343</u>
eaton-circuit-breaker-
<u>izmx-inx-mccb-</u>
dimensions-012.eps
eaton-circuit-breaker-
mounting-izmx-inx-mccb-
dimensions-002.eps
<u>eaton-circuit-breaker-</u>
mounting-izmx-inx-mccb-
<u>dimensions.eps</u>

IMPACT	antira quitabaan naada ta
IMPACI	entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
FITTED WITH:	Switched-off indicator
FRAME	IZMX16
POLLUTION DEGREE	3
RATED UNINTERRUPTED CURRENT (IU)	1000 A
MOUNTING METHOD	Withdrawable
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	125 W
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	12 kV AC
UTILIZATION CATEGORY	В
DEVICE CONSTRUCTION	Built-in device slide-in technique (withdrawable)
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Rail connection

ACTUATOR TYPE	Push button
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING	1.5 - 10 x lr
ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MAX	10000 A
ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MIN	600 A
ADJUSTMENT RANGE UNDELAYED SHORT- CIRCUIT RELEASE - MAX	15000 A
ADJUSTMENT RANGE UNDELAYED SHORT- CIRCUIT RELEASE - MIN	2000 A
AMBIENT OPERATING TEMPERATURE - MAX	70 °C
AMBIENT OPERATING TEMPERATURE - MIN	-20 °C
AMBIENT STORAGE TEMPERATURE - MAX	70 °C
AMBIENT STORAGE TEMPERATURE - MIN	-20 °C
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	2
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
NUMBER OF STANDARD MECHANICAL OPERATIONS PER HOUR - MAX	60
OPERATING SEQUENCE UP TO 690 V, 50/60 HZ (IEC/EN 60947)	42 kA
OVERLOAD RELEASE CURRENT SETTING - MAX	1000 A
OVERLOAD RELEASE CURRENT SETTING - MIN	400 A
POWER OF WITHDRAWABLE SWITCH WITH CASSETTE	125 W
RATED INSULATION	1000 V

VOLTAGE (UI)	
LIFESPAN, MECHANICAL	25000 operations (switching capacity, with maintenance) 12500 switching cycles (ON/OFF)
OVERVOLTAGE CATEGORY	III
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	0 A
WEIGHT OF CASSETTE VERSION (3-POLE)	18 kg
WEIGHT OF FIXED WITHDRAWABLE VERSION (3-POLE)	28 kg
AMBIENT OPERATING TEMPERATURE DETAILS	-20 °C - 70 °C
PROTECTION	Selective operation
VOLTAGE RATING AT AC	690 V AC
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	15000 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX	10000 A
NUMBER OF POLES	Three-pole
DEGREE OF PROTECTION	IP31 with door seals IP55 with protective cover IP31
CLOSING DELAY VIA SPRING RELEASE	30 ms
LIFESPAN, ELECTRICAL	20000 operations (switching cycles ON/OFF, with maintenance) 10000 operations (switching capacity)
ТҮРЕ	Air circuit breakers/switch- disconnectorOpen circuit breaker
SPECIAL FEATURES	 Cassette must be separately ordered. Main terminals must be separately ordered. suitable for zone

se	ectivity

- optionally fittable by user with comprehensive accessories
- Terminal capacity hint: These are values used in separate switchgear. The actual values will depend on the temperature around the circuit breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide specific and detailed

POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT

Back side

information.

RELEASE SYSTEM	Electronic release
RATED OPERATING VOLTAGE (UE) - MAX	690 V
RATED OPERATING VOLTAGE (UE) - MIN	690 V
RATED OPERATIONAL CURRENT FOR SPECIFIED	1000 A

CURRENT FOR SPECIFIED
HEAT DISSIPATION (IN)

RATED SHORT-CIRCUIT BREAKING CAPACITY AT 400 V, 50 HZ

42 kA

RATED SHORT-CIRCUIT MAKING CAPACITY UP TO 440 V, 50/60 HZ	88 kA
RATED SHORT-CIRCUIT MAKING CAPACITY UP TO 690 V, 50/60 HZ	88 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	42 kA
RATED UNINTERRUPTED CURRENT (IU) AT 50°C	1000 A
RATED UNINTERRUPTED CURRENT (IU) AT 60°C	1000 A
RATED UNINTERRUPTED CURRENT (IU) AT 70°C	1000 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN	750 A
TERMINAL CAPACITY (COPPER BAR)	5 mm x 60 mm (2x) for withdrawable units (black)
POWER LOSS	125 W

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
:	



Follow us on social media to get the Eaton House latest product and support information.

Dublin 4,











Dublin 4, Eaton.com