## Eaton 183788

Eaton Moeller series IZMX/INX - ACB. Circuitbreaker, 4 pole, 1000A, 85 kA, P measurement, IEC, Withdrawable

PRODUCT NAME	Eaton Moeller series IZMX/INX circuit-breaker
CATALOG NUMBER	183788
PRODUCT LENGTH/DEPTH	584 mm
PRODUCT HEIGHT	597 mm
PRODUCT WIDTH	521 mm
PRODUCT WEIGHT	86 kg
COMPLIANCES	IEC IEC/EN 60947 RoHS conform



Air circuit breakers/switch-disconnector Open circuit breaker  AMPERAGE RATING  1000 A  Motor drive optional Complete device with protection unit  The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.  10.11 SHORT-CIRCUIT RATING  10.12 ELECTROMAGNETIC COMPATIBILITY  10.13 MECHANICAL FUNCTION  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF THERMAL STABILITY OF INSUL. MAT. TO ABNORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  AMPORTAL ELECT. EFFECTS  10.2.5 LIFTING  AMOTO A  Motor drive optional Complete device with protect of the temperature of the temperature rise calculation. Eaton will provide heat dissipation data for the devices.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.		
FEATURES  Motor drive optional Complete device with protection unit  The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.	USED WITH	disconnector
The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.  10.11 SHORT-CIRCUIT RATING  10.12 ELECTROMAGNETIC COMPATIBILITY  10.13 MECHANICAL FUNCTION  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  Complete device with protection unit  The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  Meets the product standard's requirements.	AMPERAGE RATING	1000 A
10.10 TEMPERATURE RISE  10.11 SHORT-CIRCUIT RATING  10.11 SHORT-CIRCUIT RATING  10.12 ELECTROMAGNETIC COMPATIBILITY  10.13 MECHANICAL FUNCTION  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RISISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  10.2.5 LIFTING  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  Is the panel builder's responsibility. The specifications for the switchgear must be observed.  In device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.	FEATURES	Complete device with
10.11 SHORT-CIRCUIT RATING  responsibility. The specifications for the switchgear must be observed.  10.12 ELECTROMAGNETIC COMPATIBILITY  ls the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 MECHANICAL FUNCTION  The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  10.2.2 CORROSION Meets the product standard's requirements.  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Does not apply, since the entire switchgear needs to be evaluated.	10.10 TEMPERATURE RISE	responsible for the temperature rise calculation. Eaton will provide heat dissipation
The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  TOOR MATERIALS TO SINCE TO ULTRA-VIOLET (UV) RADIATION  The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.		responsibility. The specifications for the switchgear must be
10.13 MECHANICAL FUNCTION  requirements, provided the information in the instruction leaflet (IL) is observed.  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Meets the product standard's requirements.  Meets the product standard's requirements.  Meets the product standard's requirements.		responsibility. The specifications for the switchgear must be
RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.		requirements, provided the information in the instruction leaflet (IL) is
THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.		•
RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Meets the product standard's requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.	THERMAL STABILITY OF	•
INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Meets the product standard's requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.	RESISTANCE OF INSULATING MATERIALS	-
ULTRA-VIOLET (UV) RADIATION  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.	INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT.	-
<b>10.2.5 LIFTING</b> entire switchgear needs to be evaluated.	ULTRA-VIOLET (UV)	-
10.2.6 MECHANICAL Does not apply, since the	10.2.5 LIFTING	entire switchgear needs to
	10.2.6 MECHANICAL	Does not apply, since the

eaton-circuit-breaker-
mounting-izmx-inx-mccb-
<u>dimensions.eps</u>
eaton-circuit-breaker-
<u>izmx-inx-mccb-</u>
dimensions-015.eps
eaton-circuit-breaker-
mounting-izmx-inx-mccb-
dimensions-002.eps
<u>eaton-circuit-breaker-</u>
<u>izmx-inx-mccb-</u>
dimensions-014.eps

IMPACT	entire switchgear needs to be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	Is the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
FITTED WITH:	Switched-off indicator
FRAME	IZMX40
POLLUTION DEGREE	3
RATED UNINTERRUPTED CURRENT (IU)	1000 A
MOUNTING METHOD	Withdrawable
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	55 W
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	12 kV AC
UTILIZATION CATEGORY	В
DEVICE CONSTRUCTION	Built-in device slide-in technique (withdrawable)
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Rail connection

ACTUATOR TYPE	Push button
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING	1.5 - 10 x lr
ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MAX	10000 A
ADJUSTMENT RANGE SHORT-TERM DELAYED SHORT-CIRCUIT RELEASE - MIN	600 A
ADJUSTMENT RANGE UNDELAYED SHORT- CIRCUIT RELEASE - MAX	15000 A
ADJUSTMENT RANGE UNDELAYED SHORT- CIRCUIT RELEASE - MIN	2000 A
AMBIENT OPERATING TEMPERATURE - MAX	70 °C
AMBIENT OPERATING TEMPERATURE - MIN	-20 °C
AMBIENT STORAGE TEMPERATURE - MAX	70 °C
AMBIENT STORAGE TEMPERATURE - MIN	-20 °C
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	2
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
NUMBER OF STANDARD MECHANICAL OPERATIONS PER HOUR - MAX	60
OPERATING SEQUENCE UP TO 690 V, 50/60 HZ (IEC/EN 60947)	75 kA
OVERLOAD RELEASE CURRENT SETTING - MAX	1000 A
OVERLOAD RELEASE CURRENT SETTING - MIN	400 A
POWER OF WITHDRAWABLE SWITCH WITH CASSETTE	55 W
RATED INSULATION	1000 V

VOLTAGE (UI)	
LIFESPAN, MECHANICAL	12500 switching cycles (ON/OFF) 25000 operations (switching capacity, with maintenance)
OVERVOLTAGE CATEGORY	III
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	0 A
WEIGHT OF CASSETTE VERSION (4-POLE)	35 kg
WEIGHT OF FIXED WITHDRAWABLE VERSION (4-POLE)	86 kg
AMBIENT OPERATING TEMPERATURE DETAILS	-20 °C - 70 °C
PROTECTION	P measurement
VOLTAGE RATING AT AC	690 V AC
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	15000 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX	10000 A
NUMBER OF POLES	Four-pole
DEGREE OF PROTECTION	IP31 IP55 with protective cover IP31 with door seals
CLOSING DELAY VIA SPRING RELEASE	35 ms
LIFESPAN, ELECTRICAL	10000 operations (switching capacity) 20000 operations (switching cycles ON/OFF, with maintenance)
ТҮРЕ	<ul><li>Air circuit breakers/switch- disconnector</li><li>Open circuit breaker</li></ul>
SPECIAL FEATURES	<ul> <li>Cassette must be separately ordered.</li> <li>External IZMX-DTP- PTM-1 voltage measuring module required (1 module</li> </ul>

- is suitable for 16 circuit breakers)
- IZMX-DTP-PTM external voltage measuring module required
- suitable for zone selectivity
- suitable for communication
- with integrated system monitor
- with integrated test possibility
- With graphic LCD display
- optionally fittable by user with comprehensive accessories
- Terminal capacity hint: These are values used in separate switchgear. The actual values will depend on the temperature around the circuit breaker, which is influenced by the ambient temperature, the degree of protection (IP), the mounting height, the partitions, and any external ventilation. Depending on the specific switchgear design, this may result in derating, which can then be compensated for by increasing the cross-sectional area. Temperature rise tests in the specific switchgear can provide specific and detailed information.

CURRENT CIRCUIT	
RELEASE SYSTEM	Electronic release
RATED OPERATING VOLTAGE (UE) - MAX	690 V
RATED OPERATING VOLTAGE (UE) - MIN	690 V
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	1000 A
RATED SHORT-CIRCUIT BREAKING CAPACITY AT 400 V, 50 HZ	85 kA
RATED SHORT-CIRCUIT MAKING CAPACITY UP TO 440 V, 50/60 HZ	187 kA
RATED SHORT-CIRCUIT MAKING CAPACITY UP TO 690 V, 50/60 HZ	166 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	85 kA
RATED SHORT-TIME WITHSTAND CURRENT AT 50/60 HZ (T = 3 S)	66 kA
RATED UNINTERRUPTED CURRENT (IU) AT 50°C	1000 A
RATED UNINTERRUPTED CURRENT (IU) AT 60°C	1000 A
RATED UNINTERRUPTED CURRENT (IU) AT 70°C	1000 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN	750 A
TERMINAL CAPACITY (COPPER BAR)	60 mm x 10 mm (1x) for withdrawable units (black)
POWER LOSS	55 W
PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	



Eaton House 30 Pembroke Road Dublin 4, Eaton.com

Follow us on social media to get the latest product and support information.









