Eaton 191425

NZMN4-VX1000. NZM4 PXR20 circuit breaker, 1000A, 3p, screw terminal

PRODUCT NAME	Eaton Moeller series NZM molded case circuit breaker electronic
CATALOG NUMBER	191425
PRODUCT LENGTH/DEPTH	375 mm
PRODUCT HEIGHT	170 mm
PRODUCT WIDTH	210 mm
PRODUCT WEIGHT	19 kg
COMPLIANCES	RoHS conform
CERTIFICATIONS	IEC IEC/EN 60947



AMPERAGE RATING 1000 A VOLTAGE RATING 690 V - 690 V CIRCUIT BREAKER FRAME TYPE NZM4 FEATURES Motor drive optional Protection unit 10.10 TEMPERATURE RISE The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 MECHANICAL FUNCTION The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE Meets the product standard's requirements. 10.2.3.1 VERIFICATION OF ENCLOSURES Meets the product standard's requirements. 10.2.3.2 VERIFICATION OF ENCLOSURES Meets the product standard's requirements. 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT Meets the product standard's requirements. 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL IMPACT Does not apply, since the entire switchgear		
TOUTE BREAKER FRAME TYPE FEATURES Motor drive optional Protection unit The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.	AMPERAGE RATING	1000 A
FEATURES Motor drive optional Protection unit The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices. 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.	VOLTAGE RATING	690 V - 690 V
10.10 TEMPERATURE RISE 10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL 10.2.6 MECHANICAL The panel builder is responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the		NZM4
10.10 TEMPERATURE RISE 10.11 SHORT-CIRCUIT RATING 10.12 ELECTROMAGNETIC COMPATIBILITY 10.13 MECHANICAL FUNCTION 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF TINSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSULATING MATERIALS TO NORMAL HEAT 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING 10.2.6 MECHANICAL Tresponsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.	FEATURES	· ·
10.11 SHORT-CIRCUIT RATING responsibility. The specifications for the switchgear must be observed. Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.12 ELECTROMAGNETIC COMPATIBILITY Is the panel builder's responsibility. The specifications for the switchgear must be observed. 10.13 MECHANICAL FUNCTION The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION Meets the product standard's requirements. 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the	10.10 TEMPERATURE RISE	responsible for the temperature rise calculation. Eaton will provide heat dissipation
10.12 ELECTROMAGNETIC COMPATIBILITY responsibility. The specifications for the switchgear must be observed. The device meets the requirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the		responsibility. The specifications for the switchgear must be
Tequirements, provided the information in the instruction leaflet (IL) is observed. 10.2.2 CORROSION RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION 10.2.5 LIFTING requirements, provided the information in the instruction leaflet (IL) is observed. Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the entire switchgear needs to be evaluated.		responsibility. The specifications for the switchgear must be
RESISTANCE 10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. Does not apply, since the evaluated.		requirements, provided the information in the instruction leaflet (IL) is
THERMAL STABILITY OF ENCLOSURES 10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Meets the product standard's requirements. Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the		
RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT 10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Meets the product standard's requirements. Meets the product standard's requirements. Does not apply, since the entire switchgear needs to be evaluated.	THERMAL STABILITY OF	·
INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS 10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the	RESISTANCE OF INSULATING MATERIALS	•
ULTRA-VIOLET (UV) RADIATION Does not apply, since the entire switchgear needs to be evaluated. 10.2.6 MECHANICAL Does not apply, since the entire switchgear needs to be not apply, since the	INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT.	•
10.2.5 LIFTING entire switchgear needs to be evaluated.10.2.6 MECHANICAL Does not apply, since the	ULTRA-VIOLET (UV)	-
	10.2.5 LIFTING	entire switchgear needs to

eaton-circuit-breaker- basic-unit-bg4- il012101zu.pdf
eaton-circuit-breaker-nzm- mccb-dimensions-022.eps

	be evaluated.
10.2.7 INSCRIPTIONS	Meets the product standard's requirements.
10.3 DEGREE OF PROTECTION OF ASSEMBLIES	Does not apply, since the entire switchgear needs to be evaluated.
10.4 CLEARANCES AND CREEPAGE DISTANCES	Meets the product standard's requirements.
10.5 PROTECTION AGAINST ELECTRIC SHOCK	Does not apply, since the entire switchgear needs to be evaluated.
10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS	Does not apply, since the entire switchgear needs to be evaluated.
10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS	ls the panel builder's responsibility.
10.8 CONNECTIONS FOR EXTERNAL CONDUCTORS	ls the panel builder's responsibility.
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	ls the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	ls the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	ls the panel builder's responsibility.
POLLUTION DEGREE	3
MOUNTING METHOD	Fixed Built-in device fixed built- in technique
CLIMATIC PROOFING	Damp heat, constant, to IEC 60068-2-78 Damp heat, cyclic, to IEC 60068-2-30
EQUIPMENT HEAT DISSIPATION, CURRENT- DEPENDENT	165 W
UTILIZATION CATEGORY	B (IEC/EN 60947-2)
ISOLATION	500 V AC (between auxiliary contacts and main contacts) 300 V AC (between the auxiliary contacts)
AMBIENT OPERATING TEMPERATURE - MAX	70 °C
AMBIENT OPERATING TEMPERATURE - MIN	-25 °C
AMBIENT STORAGE	70 °C

TEMPERATURE - MAX	
AMBIENT STORAGE TEMPERATURE - MIN	40 °C
NUMBER OF AUXILIARY CONTACTS (CHANGE- OVER CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)	0
NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)	0
PROTECTION AGAINST DIRECT CONTACT	Finger and back-of-hand proof to DIN EN 50274/VDE 0106 part 110
DEGREE OF PROTECTION	IP20 (basic degree of protection, in the operating controls area) IP20
DIRECTION OF INCOMING SUPPLY	As required
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Screw connection
LIFESPAN, MECHANICAL	10000 operations
OVERVOLTAGE CATEGORY	Ш
DEGREE OF PROTECTION (IP), FRONT SIDE	IP66 (with door coupling rotary handle) IP40 (with insulating surround)
DEGREE OF PROTECTION (TERMINATIONS)	IP10 (tunnel terminal) IP00 (terminations, phase isolator and strip terminal)
NUMBER OF POLES	Three-pole
TERMINAL CAPACITY (COPPER STRIP)	10 segments of 50 mm x 1 mm (2x) at 1-hole module plate Min. 6 segments of 16 mm x 0.8 mm at flat conductor terminal Max. 10 segments of 50 mm x 1 mm (2x) at rearside connection (punched) Max. 10 segments of 32
	mm x 1 mm (2x) at flat conductor terminal Min. 5 segments of 25 mm x 1 mm at rear-side connection (punched)

	10 segments of 80 mm x 1 mm (2x) at rear-side width extension
LIFESPAN, ELECTRICAL	3000 operations at 400 V AC-1 3000 operations at 415 V AC-1 20000 operations at 690 V AC-1
FUNCTIONS	Systems, cable, selectivity and generator protection
TYPE	Circuit breaker
SPECIAL FEATURES	 LSI overload protection and delayed and non-delayed short-circuit protective device R.m.s. value measurement and "thermal memory" USB interface for configuration and test function with Power Xpert Protection Manager software Optionally communication-capable with interface module and internal Modbus RTU module or CAM Maximum back-up fuse, if the expected short-circuit currents at the installation location exceed the switching capacity of the circuit breaker (Rated short-circuit breaking capacity Icn) Rated current = rated uninterrupted current: 1000 A
APPLICATION	systems at 525 V
SHOCK RESISTANCE	15 g (half-sinusoidal shock

	11 ms)
POSITION OF CONNECTION FOR MAIN CURRENT CIRCUIT	Front side
RATED OPERATIONAL CURRENT FOR SPECIFIED HEAT DISSIPATION (IN)	1000 A
RELEASE SYSTEM	Electronic release
SHORT-CIRCUIT TOTAL BREAKTIME	< 25 ms (415 V); < 35 ms (> 415 V)
RATED SHORT-TIME WITHSTAND CURRENT (T = 0.3 S)	12 kA
RATED SHORT-TIME WITHSTAND CURRENT (T = 1 S)	12 kA
SHORT-CIRCUIT RELEASE DELAYED SETTING - MAX	10000 A
SHORT-CIRCUIT RELEASE DELAYED SETTING - MIN	800 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MAX	12000 A
SHORT-CIRCUIT RELEASE NON-DELAYED SETTING - MIN	2000 A
TERMINAL CAPACITY (CONTROL CABLE)	0.75 mm ² - 2.5 mm ² (1x) 0.75 mm ² - 1.5 mm ² (2x)
TERMINAL CAPACITY (COPPER BUSBAR)	M10 at rear-side screw connection Max. 50 mm x 10 mm (2x) at rear-side 1-hole module plate Max. 50 mm x 10 mm (2x) direct at switch rear-side connection Max. 80 mm x 10 mm (2x) at rear-side width extension 50 mm x 10 mm (2x) at rear-side 2-hole module plate Min. 25 mm x 5 mm at rear-side 1-hole module plate Min. 25 mm x 5 mm direct at switch rear-side connection Min. 60 mm x 10 mm at rear-side width extension
	2 125 3 (2)
TERMINAL CAPACITY	95 mm² - 185 mm² (2x) at

(COPPER SOLID CONDUCTOR/CABLE)	rear-side 2-hole module plate 120 mm² - 300 mm² (1x) at rear-side 1-hole module plate 50 mm² - 240 mm² (4x) at 4-hole tunnel terminal 300 mm² (4x) at rear-side width extension 35 mm² - 185 mm² (4x) at rear-side 2-hole module plate 95 mm² - 240 mm² (6x) at rear-side width extension 95 mm² - 300 mm² (2x) at rear-side 1-hole module plate
TERMINAL CAPACITY (COPPER STRANDED CONDUCTOR/CABLE)	50 mm ² - 185 mm ² (4x) direct at switch rear-side connection 120 mm ² - 185 mm ² (1x) direct at switch rear-side connection
TERMINAL CAPACITY (ALUMINUM STRANDED CONDUCTOR/CABLE)	50 mm ² - 240 mm ² (4x) at 4-hole tunnel terminal
HANDLE TYPE	Rocker lever
SHORT DELAY CURRENT SETTING (ISD) - MAX	10 A
SHORT DELAY CURRENT SETTING (ISD) - MIN	2 A
INSTANTANEOUS CURRENT SETTING (II) - MAX	18 A
INSTANTANEOUS CURRENT SETTING (II) - MIN	2 A
NUMBER OF OPERATIONS PER HOUR - MAX	60
OVERLOAD CURRENT SETTING (IR) - MAX	1000 A
OVERLOAD CURRENT SETTING (IR) - MIN	400 A
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 230 V, 50/60 HZ	37 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 400/415 V, 50/60 HZ	37 kA

RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 440 V, 50/60 HZ	26 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 525 V, 50/60 HZ	19 kA
RATED SHORT-CIRCUIT BREAKING CAPACITY ICS (IEC/EN 60947) AT 690 V, 50/60 HZ	15 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 400/415 V, 50/60 HZ	110 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 440 V, 50/60 HZ	77 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 525 V, 50/60 HZ	55 kA
RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 690 V, 50/60 HZ	40 kA
STANDARD TERMINALS	Screw terminal
OPTIONAL TERMINALS	Screw terminal Connection on rear. Strip terminal. Tunnel terminal
	Connection on rear. Strip
OPTIONAL TERMINALS RATED SHORT-CIRCUIT MAKING CAPACITY ICM	Connection on rear. Strip terminal. Tunnel terminal
OPTIONAL TERMINALS RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY	Connection on rear. Strip terminal. Tunnel terminal 110 kA
OPTIONAL TERMINALS RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN	Connection on rear. Strip terminal. Tunnel terminal 110 kA 6000 V
OPTIONAL TERMINALS RATED SHORT-CIRCUIT MAKING CAPACITY ICM AT 240 V, 50/60 HZ RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT AUXILIARY CONTACTS RATED IMPULSE WITHSTAND VOLTAGE (UIMP) AT MAIN CONTACTS RATED SHORT-CIRCUIT BREAKING CAPACITY ICU (IEC/EN 60947) AT 525 V,	Connection on rear. Strip terminal. Tunnel terminal 110 kA 6000 V

RATED SHORT-CIRCUIT BREAKING CAPACITY ICU (IEC/EN 60947) AT 690 V, 50/60 HZ

20 kA

RATED SHORT-CIRCUIT BREAKING CAPACITY ICU (IEC/EN 60947) AT 440 V,

35 kA

RATED INSULATION VOLTAGE (UI)

50/60 HZ

690 V AC

PROJECT NAME:

PROJECT NUMBER:

PREPARED BY:



Eaton House 30 Pembroke Road Dublin 4, Eaton.com

information.





latest product and support

Follow us on social media to get the



