## Eaton 199242

Eaton Moeller® series DILM Contactor, 3 pole, 380 V 400 V 5.5 kW, 1 N/O, 42 V 50 Hz, 48 V 60 Hz, AC operation, Push in terminals

PRODUCT NAME	Eaton Moeller® series DILM contactor
CATALOG NUMBER	199242
PRODUCT LENGTH/DEPTH	75 mm
PRODUCT HEIGHT	68 mm
PRODUCT WIDTH	45 mm
PRODUCT WEIGHT	0.225 kg
CERTIFICATIONS	VDE 0660 IEC/EN 60947 UL Listed CSA certified UL Category Control No.: NLDX CE marking UL File No.: E29096 CSA Class No.: 2411-03, 3211-04 CSA File No.: 012528
CATALOG NOTES	Also tested according to AC-3e.



The panel builder is responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.  10.11 SHORT-CIRCUIT RATING  10.12 Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 MECHANICAL FUNCTION  10.13 MECHANICAL FUNCTION  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEATFIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  10.2.5 LIFTING  10.2.6 MECHANICAL IMPACT  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.3 DEGREE OF PROTECTION OF entire switchgear needs to be evaluated.  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION OF entire switchgear needs to be evaluated.  10.6 INCORPORATION OF SASEMBLIES  10.7 INTERNAL ELECTRIC SHOCK  10.8 CONNECTIONS FOR External Entire switchgear needs to be evaluated.  10.8 CONNECTIONS FOR Is the panel builder's responsibility.	MIMBED OF BOLES	Thurst
10.10 TEMPERATURE RISE  responsible for the temperature rise calculation. Eaton will provide heat dissipation data for the devices.  10.11 SHORT-CIRCUIT RATING  11.12 Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.12 Is the panel builder's responsibility. The specifications for the switchgear must be observed.  10.13 MECHANICAL FUNCTION  10.13 MECHANICAL FUNCTION  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  10.2.5 LIFTING  10.2.6 MECHANICAL IMPACT  10.2.7 INSCRIPTIONS  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  10.3 DEGREE OF PROTECTION OF RASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION AGAINST ELECTRIC SHOP CONNECTIONS  Meets the product standard's requirements.  10.5 PROTECTION OF ASSEMBLIES  10.6 INCORPORATION OF SWITCHING DEVICES AND CONNECTIONS  Is the panel builder's responsibility. The sponsibility. The sponsibility. The sponsibility. The sponsibility. The sponsibility is the panel builder's responsibility. The sponsibility. The sponsibility. The sponsibility. The sponsibility. The sponsibility. The sponsibility. The sponsibility is the panel builder's responsibility.	NUMBER OF POLES	Three-pole
10.11 SHORT-CIRCUIT RATING  responsibility. The specifications for the switchgear must be observed.  10.12  ELECTROMAGNETIC COMPATIBILITY  10.13 MECHANICAL FUNCTION  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSUL. MAT. TO ABNORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULITRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  10.2.5 LIFTING  10.2.6 MECHANICAL INPACT  10.2.7 INSCRIPTIONS  10.3 DEGREE OF PROTECTION OF ASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION OF ASSEMBLIES  10.6 INCORPORATION OF SWITCHING DOEs not apply, since the entire switchgear needs to be evaluated.  10.5 PROTECTION OF SASSEMBLIES  10.6 INCORPORATION OF SWITCHING DOEs not apply, since the entire switchgear needs to be evaluated.  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.7 INTERNAL ELECTION OF SWITCHING DEVICES AND COMPONENTS  10.8 CONNECTIONS Is the panel builder's responsibility.  10.8 CONNECTIONS Is the panel builder's responsibility.		responsible for the temperature rise calculation. Eaton will provide heat dissipation data
ELECTROMAGNETIC COMPATIBILITY  responsibility. The specifications for the switchgear must be observed.  The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.  10.2.2 CORROSION RESISTANCE  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.3 DEGREE OF PROTECTION OF ASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION AGAINST ELECTRIC SHOCK  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.8 CONNECTIONS FOR  Is the panel builder's responsibility.		responsibility. The specifications for the
10.13 MECHANICAL FUNCTION requirements, provided the information in the instruction leaflet (IL) is observed.  10.2.2 CORROSION Meets the product standard's requirements.  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION Does not apply, since the entire switchgear needs to be evaluated.  10.5 PROTECTION Does not apply, since the entire switchgear needs to be evaluated.  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.7 INTERNAL ELECTRIC SHOCK Is the panel builder's responsibility.	ELECTROMAGNETIC	responsibility. The specifications for the
RESISTANCE requirements.  10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Incomposition of the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Incomposition of the product standard's requirements.		requirements, provided the information in the instruction
OF THERMAL STABILITY OF ENCLOSURES  10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  Does not apply, since the entire switchgear needs to be evaluated.  10.2.6 MECHANICAL IMPACT  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.3 DEGREE OF PROTECTION OF ASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES 10.5 PROTECTION AGAINST ELECTRIC SHOCK  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.8 CONNECTIONS FOR  Meets the product standard's requirements.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.		
OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT  10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  10.2.5 LIFTING  Does not apply, since the entire switchgear needs to be evaluated.  10.2.6 MECHANICAL Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.3 DEGREE OF PROTECTION OF ASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION Does not apply, since the entire switchgear needs to be evaluated.  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.7 INTERNAL ELECTRIC SHOCK Is the panel builder's responsibility.  10.8 CONNECTIONS FOR Is the panel builder's	OF THERMAL STABILITY	
MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS  10.2.4 RESISTANCE TO ULTRA-VIOLET (UV) RADIATION  Does not apply, since the entire switchgear needs to be evaluated.  10.2.5 LIFTING  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  10.2.7 INSCRIPTIONS  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Los PROTECTION AGAINST ELECTRIC SHOCK  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Los PROTECTION of SWITCHING DEVICES AND COMPONENTS  Is the panel builder's responsibility.	OF RESISTANCE OF INSULATING MATERIALS TO	
ULTRA-VIOLET (UV) RADIATION  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  In the panel builder's responsibility.  Is the panel builder's responsibility.	MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT.	
10.2.5 LIFTING entire switchgear needs to be evaluated.  10.2.6 MECHANICAL IMPACT  10.2.7 INSCRIPTIONS  10.3 DEGREE OF PROTECTION OF ASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION  AGAINST ELECTRIC SHOCK  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS  10.8 CONNECTIONS FOR  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.	ULTRA-VIOLET (UV)	
IMPACT  entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Meets the product standard's requirements.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Interval Lectric Switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's	10.2.5 LIFTING	entire switchgear needs to be
10.3 DEGREE OF PROTECTION OF ASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION  AGAINST ELECTRIC SHOCK  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS  10.8 CONNECTIONS FOR  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.		entire switchgear needs to be
PROTECTION OF ASSEMBLIES  10.4 CLEARANCES AND CREEPAGE DISTANCES  10.5 PROTECTION AGAINST ELECTRIC SHOCK  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS  10.8 CONNECTIONS FOR  entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.  Is the panel builder's	10.2.7 INSCRIPTIONS	
CREEPAGE DISTANCES requirements.  10.5 PROTECTION    AGAINST ELECTRIC    SHOCK  10.6 INCORPORATION OF    SWITCHING DEVICES    AND COMPONENTS  10.7 INTERNAL    ELECTRICAL CIRCUITS    AND CONNECTIONS  10.8 CONNECTIONS FOR  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.	PROTECTION OF	entire switchgear needs to be
AGAINST ELECTRIC SHOCK  10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS  10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS  10.8 CONNECTIONS FOR  entire switchgear needs to be evaluated.  Does not apply, since the entire switchgear needs to be evaluated.  Is the panel builder's responsibility.		
SWITCHING DEVICES AND COMPONENTS  entire switchgear needs to be evaluated.  10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS  10.8 CONNECTIONS FOR  Is the panel builder's responsibility.	AGAINST ELECTRIC	entire switchgear needs to be
ELECTRICAL CIRCUITS AND CONNECTIONS  10.8 CONNECTIONS FOR  Is the panel builder's responsibility.  Is the panel builder's responsibility.	SWITCHING DEVICES	entire switchgear needs to be
	ELECTRICAL CIRCUITS	

	dil m7 15 pi.dwg
MCAD MODEL	eaton-iec-contactors-mcad-3d-models-dil-m7-15-pi.stp
	eaton-contactors-dimensions- 007.eps

CONDUCTORS	
10.9.2 POWER- FREQUENCY ELECTRIC STRENGTH	Is the panel builder's responsibility.
10.9.3 IMPULSE WITHSTAND VOLTAGE	Is the panel builder's responsibility.
10.9.4 TESTING OF ENCLOSURES MADE OF INSULATING MATERIAL	Is the panel builder's responsibility.
OPERATING FREQUENCY	9000 mechanical Operations/h (AC operated)
POLLUTION DEGREE	3
CLIMATIC PROOFING	Damp heat, cyclic, to IEC 60068-2-30 Damp heat, constant, to IEC 60068-2-78
CONNECTION TO SMARTWIRE-DT	No
RATED IMPULSE WITHSTAND VOLTAGE (UIMP)	6000 V AC
UTILIZATION CATEGORY	AC-1: Non-inductive or slightly inductive loads, resistance furnaces AC-4: Normal AC induction motors: starting, plugging, reversing, inching AC-3: Normal AC induction motors: starting, switch off during running
CONNECTION	Push in terminals
CONNECTION FRAME SIZE	Push in terminals FS1
FRAME SIZE AMBIENT OPERATING	FS1
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING	FS1 60 °C
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  AMBIENT OPERATING TEMPERATURE	FS1 60 °C -25 °C
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX  AMBIENT OPERATING TEMPERATURE	FS1 60 °C -25 °C 40 °C
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN  AMBIENT STORAGE	FS1 60 °C -25 °C 40 °C -25 °C
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN  AMBIENT STORAGE TEMPERATURE - MAX  AMBIENT STORAGE	FS1 60 °C -25 °C 40 °C -25 °C 80 °C
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN  AMBIENT STORAGE TEMPERATURE - MAX  AMBIENT STORAGE TEMPERATURE - MIN  ASSIGNED MOTOR POWER AT 115/120 V, 60	FS1 60 °C -25 °C 40 °C -25 °C -25 °C -20 °C
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN  AMBIENT STORAGE TEMPERATURE - MAX  AMBIENT STORAGE TEMPERATURE - MIN  ASSIGNED MOTOR POWER AT 115/120 V, 60  HZ, 1-PHASE  ASSIGNED MOTOR POWER AT 200/208 V, 60	FS1 60 °C -25 °C 40 °C -25 °C 80 °C -40 °C
FRAME SIZE  AMBIENT OPERATING TEMPERATURE - MAX  AMBIENT OPERATING TEMPERATURE - MIN  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MAX  AMBIENT OPERATING TEMPERATURE (ENCLOSED) - MIN  AMBIENT STORAGE TEMPERATURE - MAX  AMBIENT STORAGE TEMPERATURE - MIN  ASSIGNED MOTOR POWER AT 115/120 V, 60 HZ, 1-PHASE  ASSIGNED MOTOR POWER AT 200/208 V, 60 HZ, 3-PHASE  ASSIGNED MOTOR POWER AT 230/240 V, 60	FS1 60 °C -25 °C 40 °C -25 °C 80 °C -40 °C 1 HP 3 HP

HZ, 3-PHASE	
ASSIGNED MOTOR POWER AT 575/600 V, 60 HZ, 3-PHASE	10 HP
CONVENTIONAL THERMAL CURRENT ITH (1-POLE, ENCLOSED)	45 A
CONVENTIONAL THERMAL CURRENT ITH (3-POLE, ENCLOSED)	18 A
CONVENTIONAL THERMAL CURRENT ITH AT 55°C (3-POLE, OPEN)	21 A
CONVENTIONAL THERMAL CURRENT ITH OF MAIN CONTACTS (1- POLE, OPEN)	50 A
HEAT DISSIPATION CAPACITY PDISS	0 W
APPLICATION	Contactors for Motors
PRODUCT CATEGORY	Contactors
PROTECTION	Finger and back-of-hand proof, Protection against direct contact when actuated from front (EN 50274)
ARCING TIME	10 ms
ELECTRICAL CONNECTION TYPE OF MAIN CIRCUIT	Push-in connection
SCREWDRIVER SIZE	3.0 x 0.5 mm, Terminal screw
	3 x 0.5 mm, Terminal screw
VOLTAGE TYPE	AC AC
VOLTAGE TYPE  DEGREE OF PROTECTION	
DEGREE OF	AC
DEGREE OF PROTECTION NUMBER OF AUXILIARY CONTACTS (NORMALLY	AC IP20
DEGREE OF PROTECTION NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS) NUMBER OF AUXILIARY CONTACTS (NORMALLY	AC IP20 0
DEGREE OF PROTECTION  NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)  NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF CONTACTS (NORMALLY CLOSED) AS	AC IP20 0 1
DEGREE OF PROTECTION  NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)  NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF CONTACTS (NORMALLY CLOSED) AS MAIN CONTACT  NUMBER OF CONTACTS (NORMALLY OPEN)	AC IP20 0 1 0 0
DEGREE OF PROTECTION  NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)  NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF CONTACTS (NORMALLY CLOSED) AS MAIN CONTACT  NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACTS)	AC IP20 0 1 1
DEGREE OF PROTECTION  NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)  NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF CONTACTS (NORMALLY CLOSED) AS MAIN CONTACT NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACT)  RATED BREAKING	AC IP20 0 1 1 3
DEGREE OF PROTECTION  NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)  NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF CONTACTS (NORMALLY CLOSED) AS MAIN CONTACT NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACT)  RATED BREAKING CAPACITY AT 220/230 V  RATED BREAKING	AC IP20 0 1 1 3 120 A
DEGREE OF PROTECTION  NUMBER OF AUXILIARY CONTACTS (NORMALLY CLOSED CONTACTS)  NUMBER OF AUXILIARY CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF CONTACTS (NORMALLY CLOSED) AS MAIN CONTACT (NORMALLY CLOSED) AS MAIN CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF CONTACTS (NORMALLY OPEN CONTACTS)  NUMBER OF MAIN CONTACTS (NORMALLY OPEN CONTACT)  RATED BREAKING CAPACITY AT 220/230 V  RATED BREAKING CAPACITY AT 380/400 V  RATED BREAKING	AC IP20 0 1 1 3 120 A

AT AC, 50 HZ - MAX	
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 50 HZ - MIN	42 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MAX	48 V
RATED CONTROL SUPPLY VOLTAGE (US) AT AC, 60 HZ - MIN	48 V
OVERVOLTAGE CATEGORY	III
DUTY FACTOR	100 %
EMITTED INTERFERENCE	According to EN 60947-1
INTERFERENCE IMMUNITY	According to EN 60947-1
LIFESPAN, MECHANICAL	10,000,000 Operations (AC operated)
PICK-UP VOLTAGE	0.8 - 1.1 V AC x Uc
POWER CONSUMPTION, PICK-UP, 50 HZ	24 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz
SAFE ISOLATION	400 V AC, Between coil and contacts, According to EN 61140 400 V AC, Between the contacts, According to EN 61140
POWER CONSUMPTION, PICK-UP, 60 HZ	30 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz
POWER CONSUMPTION, SEALING, 50 HZ	3.4 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz 1.4 W, Dual-frequency coil in a cold state and 1.0 x Us, at 50 Hz
POWER CONSUMPTION, SEALING, 60 HZ	1.4 W, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz 4.4 VA, Dual-frequency coil in a cold state and 1.0 x Us, at 60 Hz
TERMINAL CAPACITY (FLEXIBLE WITH UNISOLATED FERRULE)	1 x (0.5 - 2.5) mm <sup>2</sup> 2 x (0.5 - 2.5) mm <sup>2</sup>
TERMINAL CAPACITY (FLEXIBLE WITH ULTRASONIC WELDED CABLE END)	1 x (0.5 - 2.5) mm <sup>2</sup> 2 x (0.5 - 2.5) mm <sup>2</sup>
SWITCHING CAPACITY (AUXILIARY CONTACTS, GENERAL USE)	1 A, 250 V DC, (UL/CSA) 10 A, 600 V AC, (UL/CSA)
SWITCHING CAPACITY (AUXILIARY CONTACTS, PILOT DUTY)	A600, AC operated (UL/CSA) P300, DC operated (UL/CSA)
TERMINAL CAPACITY (FLEXIBLE WITH FERRULE)	1 x (0.5 - 2.5) mm <sup>2</sup> 2 x (0.5 - 1.5) mm <sup>2</sup>
SHOCK RESISTANCE	7 g, N/O auxiliary contact,

Mechanical, according to
IEC/EN 60068-2-27, Half-
sinusoidal shock 10 ms
5 g, N/C auxiliary contact,
Mechanical, according to
IEC/EN 60068-2-27, Half-
sinusoidal shock 10 ms
5.7 g, N/O main contact,
Mechanical, according to
IEC/EN 60068-2-27 when
tabletop-mounted, Half-
sinusoidal shock 10 ms
3.4 g, N/O auxiliary contact,
Mechanical, according to
IEC/EN 60068-2-27 when
tabletop-mounted, Half-
sinusoidal shock 10 ms
10 g, N/O main contact,
Mechanical, according to
IEC/EN 60068-2-27, Half-
sinusoidal shock 10 ms
3.4 g, N/C auxiliary contact,
Mechanical, according to
IEC/EN 60068-2-27 when
tabletop-mounted, Half-
sinusoidal shock 10 ms

	sinusoidal shock 10 ms
TERMINAL CAPACITY (SOLID)	1 x (0.5 - 2.5) mm <sup>2</sup> 2 x (0.5 - 2.5) mm <sup>2</sup>
TERMINAL CAPACITY (SOLID/STRANDED AWG)	20 - 14
SWITCHING CAPACITY (MAIN CONTACTS, GENERAL USE)	20 A, Maximum motor rating (UL/CSA)
TERMINAL CAPACITY (FLEXIBLE)	2 x (0.5 - 2.5) mm <sup>2</sup> 1 x (0.5 - 2.5) mm <sup>2</sup>
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MAX	0 V
RATED CONTROL SUPPLY VOLTAGE (US) AT DC - MIN	0 V
RATED INSULATION VOLTAGE (UI)	690 V
RATED MAKING CAPACITY UP TO 690 V (COS PHI TO IEC/EN 60947)	144 A
RATED OPERATIONAL CURRENT (IE) AT AC-1, 380 V, 400 V, 415 V	22 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 220 V, 230 V, 240 V	12 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 380 V, 400 V, 415 V	12 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 440 V	12 A
RATED OPERATIONAL CURRENT (IE) AT AC-3, 500 V	10 A
RATED OPERATIONAL CURRENT (IE) AT AC-3,	7 A

660 V, 690 V	
RATED OPERATIONAL CURRENT (IE) AT AC-4, 220 V, 230 V, 240 V	7 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 400 V	7 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 440 V	7 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 500 V	6 A
RATED OPERATIONAL CURRENT (IE) AT AC-4, 660 V, 690 V	5 A
RATED OPERATIONAL CURRENT (IE) AT DC-1, 110 V	20 A
RATED OPERATIONAL CURRENT (IE) AT DC-1, 220 V	15 A
RATED OPERATIONAL CURRENT (IE) AT DC-1, 60 V	20 A
RATED OPERATIONAL POWER AT AC-3, 240 V, 50 HZ	4 kW
RATED OPERATIONAL POWER AT AC-3, 380/400 V, 50 HZ	5.5 kW
RATED OPERATIONAL POWER AT AC-3, 415 V, 50 HZ	7 kW
RATED OPERATIONAL POWER AT AC-4, 220/230 V, 50 HZ	2 kW
RATED OPERATIONAL POWER AT AC-4, 240 V, 50 HZ	2.2 kW
RATED OPERATIONAL POWER AT AC-4, 380/400 V, 50 HZ	3 kW
RATED OPERATIONAL POWER AT AC-4, 415 V, 50 HZ	3.4 kW
RATED OPERATIONAL POWER AT AC-4, 440 V, 50 HZ	3.6 kW
RATED OPERATIONAL POWER AT AC-4, 500 V, 50 HZ	3.5 kW
RATED OPERATIONAL POWER AT AC-4, 660/690 V, 50 HZ	4.4 kW
RATED OPERATIONAL POWER (NEMA)	0 kW
RATED OPERATIONAL VOLTAGE (UE) AT AC - MAX	690 V

RESISTANCE PER POLE	2.5 mΩ
STRIPPING LENGTH (MAIN CABLE)	10 mm
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, CLOSING DELAY) - MAX	21 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, CLOSING DELAY) - MIN	15 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MAX	18 ms
SWITCHING TIME (AC OPERATED, MAKE CONTACTS, OPENING DELAY) - MIN	9 ms
SHORT-CIRCUIT CURRENT RATING (BASIC RATING)	5 kA, 45 A max. fuse, SCCR (UL/CSA) 5 kA, 45 A max. CB, SCCR (UL/CSA)
SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 480 V)	100 kA, 45 A CLASS J max. fuse, SCCR (UL/CSA) 30 kA, 25 A CLASS RK5 max. fuse, SCCR (UL/CSA)
SHORT-CIRCUIT CURRENT RATING (HIGH FAULT AT 600 V)	100 kA, 45 A CLASS J max. fuse, SCCR (UL/CSA) 30 kA, 25 A CLASS RK5 max. fuse, SCCR (UL/CSA)
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 400 V	35 A gG/gL
SUITABLE FOR	Also motors with efficiency class IE3
SHORT-CIRCUIT PROTECTION RATING (TYPE 1 COORDINATION) AT 690 V	25 A gG/gL
SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION) AT 400 V	20 A gG/gL
SHORT-CIRCUIT PROTECTION RATING (TYPE 2 COORDINATION) AT 690 V	20 A gG/gL
SPECIAL PURPOSE RATING OF BALLAST ELECTRICAL DISCHARGE LAMPS	20 A (480V 60Hz 3phase, 277V 60Hz 1phase) 20 A (600V 60Hz 3phase, 347V 60Hz 1phase)
SPECIAL PURPOSE RATING OF DEFINITE PURPOSE RATING	12 A, FLA 480 V 60 Hz 3-ph, 100,000 cycles acc. to UL 1995, (UL/CSA) 72 A, LRA 480 V 60 Hz 3-ph, 100,000 cycles acc. to UL 1995, (UL/CSA)
SPECIAL PURPOSE RATING OF ELEVATOR CONTROL	2 HP, 200 V 60 Hz 3-ph, (UL/CSA) 2 HP, 240 V 60 Hz 3-ph, (UL/CSA)

	7.8 A, 200 V 60 Hz 3-ph, (UL/CSA) 6.8 A, 240 V 60 Hz 3-ph, (UL/CSA) 11 A, 480 V 60 Hz 3-ph, (UL/CSA) 7.5 HP, 600 V 60 Hz 3-ph, (UL/CSA) 9 A, 600 V 60 Hz 3-ph, (UL/CSA) 7.5 HP, 480 V 60 Hz 3-ph, (UL/CSA)
SPECIAL PURPOSE RATING OF REFRIGERATION CONTROL (CSA ONLY)	10 A, FLA 480 V 60 Hz 3phase; (CSA) 10 A, FLA 600 V 60 Hz 3phase; (CSA) 60 A, LRA 480 V 60 Hz 3phase; (CSA) 60 A, LRA 600 V 60 Hz 3phase; (CSA)
SPECIAL PURPOSE RATING OF RESISTANCE AIR HEATING	20 A, 480 V 60 Hz 3phase, 277 V 60 Hz 1phase, (UL/CSA) 20 A, 600 V 60 Hz 3phase, 347 V 60 Hz 1phase, (UL/CSA)
SPECIAL PURPOSE RATING OF TUNGSTEN INCANDESCENT LAMPS	14 A, 480 V 60 Hz 3phase, 277 V 60 Hz 1phase, (UL/CSA) 14 A, 600 V 60 Hz 3phase, 347 V 60 Hz 1phase, (UL/CSA)
OPERATING VOLTAGE AT AC, 50 HZ - MIN	24 V
OPERATING VOLTAGE AT AC, 50 HZ - MAX	690 V
OPERATING VOLTAGE AT AC, 60 HZ - MIN	24 V
OPERATING VOLTAGE AT AC, 60 HZ - MAX	690 V

PROJECT NAME:	
PROJECT NUMBER:	
PREPARED BY:	
:	



Follow us on social media to get the latest product and support information.









