



□□□□

Eaton 230110

Eaton Moeller® series DILM Replacement coil, Tool-less plug connection, RAC 48: 42 - 48 V 50/60 Hz, AC, For use with: DILM115, DILM150, DILM170

□□□□

PRODUCT NAME	Eaton Moeller® series DILM replacement coil
CATALOG NUMBER	230110
PRODUCT LENGTH/DEPTH	51 mm
PRODUCT HEIGHT	110 mm
PRODUCT WIDTH	63.2 mm
PRODUCT WEIGHT	0.245 kg
CERTIFICATIONS	CE CSA-C22.2 No. 14-05 UL UL File No.: E29096 CSA CSA Class No.: 2411-03, 3211-04 UL 508 UL Category Control No.: NLDX CSA File No.: 012528 IEC/EN 60947-4-1



Powering Business Worldwide

ACCESSORIES

Individual coils

10.11 SHORT-CIRCUIT RATING

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.12 ELECTROMAGNETIC COMPATIBILITY

Is the panel builder's responsibility. The specifications for the switchgear must be observed.

10.13 MECHANICAL FUNCTION

The device meets the requirements, provided the information in the instruction leaflet (IL) is observed.

10.2.2 CORROSION RESISTANCE

Meets the product standard's requirements.

10.2.3.1 VERIFICATION OF THERMAL STABILITY OF ENCLOSURES

Meets the product standard's requirements.

10.2.3.2 VERIFICATION OF RESISTANCE OF INSULATING MATERIALS TO NORMAL HEAT

Meets the product standard's requirements.

10.2.3.3 RESIST. OF INSUL. MAT. TO ABNORMAL HEAT/FIRE BY INTERNAL ELECT. EFFECTS

Meets the product standard's requirements.

10.2.5 LIFTING

Does not apply, since the entire switchgear needs to be evaluated.

10.2.6 MECHANICAL IMPACT

Does not apply, since the entire switchgear needs to be evaluated.

10.2.7 INSCRIPTIONS

Meets the product standard's requirements.

10.3 DEGREE OF PROTECTION OF ASSEMBLIES

Does not apply, since the entire switchgear needs to be evaluated.

10.4 CLEARANCES AND CREEPAGE DISTANCES

Meets the product standard's requirements.

10.5 PROTECTION AGAINST ELECTRIC SHOCK

Does not apply, since the entire switchgear needs to be evaluated.

10.6 INCORPORATION OF SWITCHING DEVICES AND COMPONENTS

Does not apply, since the entire switchgear needs to be evaluated.

10.7 INTERNAL ELECTRICAL CIRCUITS AND CONNECTIONS

Is the panel builder's responsibility.

